

**COUNTY OF TUSCOLA
DEPARTMENT OF BUILDINGS AND GROUNDS**

125 W. Lincoln St
CARO, MI 48723

MICHAEL MILLER
Director

THOMAS MCLANE
Assistant Director

TO: INTERESTED CONTRACTORS

FROM: MIKE MILLER

DATE: August 8, 2017

RE: Water line

Tuscola County will be accepting bids on the installation of a new water line at Vanderbilt Park. The following specifications shall be considered in your bid:

Location: 4446 Bath RD Fairgrove, MI 48733

1. Contractor shall provide a 1 (ONE) inch Copper line from curb stop to inside storage building.
2. Length of run is approximately 240 feet.
3. Copper shall be K-type for underground installation. Line is to be installed at a minimum of 4 foot deep (48 inches) either by boring or trenching.
4. Contractor shall provide necessary plumbing inside the building for the meter and for an outdoor hose bib. (Meter to be supplied by Bay County)
5. Contractor will have to saw cut the existing concrete floor in the storage building to allow new line access. Once line is installed and protected, floor shall be patched to original finish.
6. The storage building is an unheated space and contractor must provide enough clearance for easy installation and removal of the meter for the seasons.
7. Contractor shall install 1(one) hose bib on the northeast corner of the building, plumbed from meter, to allow access to campers for fill water tanks.
8. Contractor shall provide the necessary protection to the public during construction process, including but not limited to barrier tape or fence
9. Contractor shall repair and damage to lawn, including but no limited to grading and reseeding.

Contractor shall provide any needed permits to complete this project and must follow all local, State, and Federal construction codes.

Call Miss DIG (811) prior to any ground disturbance.

Contractor shall provide copies of liability and worker's comp insurance, before work can begin.

State Recreation Passport grant funding is being used for this project.

Only **Sealed** proposals labeled "Park Water Line" shall be submitted to the Tuscola County Controllars office 125 W. Lincoln st, Caro, and MI 48723 no later than 4:00pm August 18, 2017.

Please call Mike Miller if you have questions- 989-672-3756 or see website at www.tuscolacounty.org

Disclaimer

Tuscola County reserves the right at its sole discretion to reject any and all proposals received without penalty and not to enter a contract as a result of this RFP. The County also reserves the right to negotiate separately with any source whatsoever in any manner necessary to attend to the best interests of the County, to waive irregularities in any proposal and to accept a proposal which best meets the needs of the County, irrespective of the bid price."

By submitting a bid, the bidder is acknowledging that there will be no contractual relationship between Tuscola County and the bidder until both parties have formally approved and signed a written contract to be developed by Tuscola County legal counsel.

The County reserves the right to make an award without further discussion of any proposal submitted. Therefore, the proposal should be submitted initially on the most favorable terms which the offer can propose. There will be no best and final offer procedure. The County does reserve the right to contact an offer for clarification of its proposal."



Nature Trail

Gilmore Rd

Gager Rd

Bath Rd

Proposed Improved Entrance Lane

Utility

Restrooms

Swing

Pavilion

Parking

Vanderbilt Rd

Donor

Sign

Curbstop

240'
1" WATER
LINE
(NEW)

VANDERBILT COUNTY PARK and CAMPGROUND

□ Camp Sites

⊕ Electric

⊗ Night Light

⊞ 6 Proposed New Picnic Tables

○ 18 Proposed New Fire Rings

